

ANNEXURE -I

(Annexure to G.O.Ms.No.56, Home (Ser.IV) Department, Dated: 26.07.2019)


Instructions to Be Followed For School Existing Before 13.04.2009:


SELF CERTIFICATION FORM

Self Certification Of Fire Safety Measures By School Management:

I) General Information for School Buildings of all Categories i.e., A, B, C, D.

Sl. No.	Details	
1.	Date Of The Opening Of The School Building	2004
2.	Name Of Applicant	M. NIZAMAKI KHAN
3.	Name And Address Of The School	ST. RITA HIGH SCHOOL, F.C.I. - Widiacolony, Miyapur, HYD
4.	Telephone Number And Email Of Applicant	9959777001
5.	Height Of The Building (In Meters)	12mtrs
6.	No Of Floors	G+3
7.	Abutting Road Width (In Meters)	
8.	Built Up Area Of Each Floor in Sq.Mtrs Stilt----- Ground ----- Floor 1----- Floor 2-----	195sqm 195sqm 195sqm 195sqm
9.	Number Of Stair Case Stair Case 1 ----- (Width In Meters) Stair Case 2 ----- (Width In Meters)	1 2mtrs
10.	Width Of Each Stair Case	10feet
11.	Open Spaces Front----- (Width In Meters) Side 1----- (Width In Meters) Side 2----- (Width In Meters) Rear ----- (Width In Meters)	10mtrs 4mtrs 2mtrs 2mtrs




 Signature with date of
 School authority and seal
 Correspondent
 St. Rita High School
 FCI-WIDIA Colony, Miyapur
 Hyderabad-500 049

A) School buildings with ground floor or ground plus one upper floor.

Sl. No	Fire equipment as per norms	Scale of fire equipment as per norms	Required	Provided
				Yes/No
1	Fire extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguishers ,for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meters radius		NA
2	Automatic sprinkler system(IS151505:2002), This IS standard may be downloaded from www.https://bis.gov.in/	To be installed in basement. If area exceeds 200 square maters		

Note: For Ground +1 floor building, if the floor area in a single floor is more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal Steel structure.

Signature with date of
School authority and seal

B) School Building with Ground plus two floors and less than 15Meters in height.

Sl. No	Fire equipment as per norms	Scale of fire equipment as per norms	Required	Provided
				Yes/No
1	Fire extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguishers ,for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meters radius	Fire Equipment provided	Yes
2	First Aid Hose Reel (IS 884:1985)	1 No for every 1000 square meter	Yes	Yes
3	Terrace Tank over respective tower terrace	10000 Liters (5000 Liters additionally shall be provided if basement exceeds 200 square meters)	Yes	Yes
4	Automatic sprinkler system(IS 151505:2002), This IS standard may be downloaded from www.https://bis.gov.in/	To be installed in basement. If area exceeds 200 square maters	-	-
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 3.5 kg/cm ²	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)	450 LPM	Yes

Additional Fire Safety Measures in lieu of deficiency in Setbacks.


1	Water Shower curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.	Yes	Yes
2	Fire Brigade inlet	02 No.s	01	01

Note: If the floor area in a single floor more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal steel structure.


Signature with date of School authority and seal
 Correspondent
 St. Rita High School
 FCI-WIDIA Colony, Miyapur
 Hyderabad-500 049

C) School Buildings with 15 Meters and above but not exceeding 24 Meters in height.

Sl. No	Fire equipment as per norms	Scale of fire equipment as per norms	Required	Provided
				Yes/No
1	Fire extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire Extinguishers ,for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meters radius	NA	/



4	<u>Water supply:</u> Underground static water storage tank with combined capacity for Wet riser, Yard hydrant and Sprinklers	50000 Liters additionally will be provided.		
5	Pump near underground static water storage tank (Fire Pump) with minimum pressure of 3.5 kg/cm ² at remotest location(Note: up gradation of fire pumps capacity instead of Sl.No.9)	Provide on Electric and one Diesel Pump (Standby) of capacity 2280 LPM and one electric pump of capacity 180 liter/min. These will be additionally provided.		
6	Risk Assessment by fire engineer	Risk assessment to be done by qualified fire engineer and any additional fire safety measures advised shall be provided.		


 Correspondent
 Signature with date of
 School authority and seal
St Rita High School
 FCI-WIDIA Colony, Miyapur
 Hyderabad-500 049


II) General Fire Safety Measures which should be followed by all schools:-

Sl. No	General Fire Safety Measures	Whether followed Yes/No
1	The school building shall not be housed in temporary structures with roofs of tent cloth, thatched or any other combustible materials.	Yes
2	It should be ensured that the available Fire Safety Equipment is always in good working condition.	Yes
3	Pre-School, Kinder Garden and Class/Grade 1 students shall be located on Ground Floor/ level of Exit discharge and Class/Grade 2 students shall be located not above One Floor higher than Ground Floor/ Level of Exit discharge.	Yes
4	Kitchen should be constructed/provided away from the school building	-
5	All schools shall prepare an Evacuation Plan in consultation with local Fire Officer	Yes
6	All Teachers/Employees should be trained in operating the available Fire Safety Equipment in the building.	Yes
7	All Exits/Escapes routes shall be kept free from any obstructions for free passage in case of any emergency.	Yes
8	All the internal staircases, lifts, lobbies and corridors should be adequately ventilated and illuminated.	Yes
9	If the school is provided with central Air-conditioning system, all safety measures as per Clause 10.1 of IS 14435:1997 should be followed.	-
10	School buildings shall be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safely.	Yes
11	Any Hazardous/Combustible Material/Volatile Flammable Liquids shall not be stored in School Building	-
12	Do's and DON'Ts in case of any Fire/Emergency shall be properly displayed at Strategic locations of the building.	Yes
13	Auto Glow Sign Boards shall be provided indicating Exits/Escapes Routes.	Yes
14	Electric Wiring in the entire building shall be checked and certified by the competent authority.	Yes

15	Structural Stability of the building shall be checked and certified by the competent authority	Yes
16	Public Address System shall be provided for use in case of any emergency and this system shall cover the entire building	Yes
17	Detailed information regarding the number of Students in each Class Room and the number of teachers/employees working shall be displayed at Strategic locations of the building.	Yes
18	Display all Emergency supporting numbers such as nearest Fire Stations, Police Stations, Hospitals/Ambulance etc., on all floors and Strategic locations.	Yes
19	A pictorial map with the details of Entries/Exits, details of Class Rooms/Laboratories/Staff Rooms and Open Place(Assembly Point) of the School Building shall be prepared and displayed in Strategic Locations.	Yes
20	If Basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler System as per IS 15105:2002	—

We M. NIZAM ALI KHAN (ST. RITA EDUCATIONAL (ST. RITA HIGH SCHOOL) School Management/Correspondent hereby

certify that the information furnished is correct and if it is noticed at any time that the information provided is false, we understand that our school affiliation may be cancelled by the Concerned Authority. We have installed fire safety measures as per the Annexure I and undertake to maintain the same in good working condition at all times.


Signature with date of
School authority and seal
Name & Designation:
Correspondent

St. Rita High School
FCI-WIDIA Colony, Miyapur
Hyderabad-500 049.

Copy to:
The Divisional Fire Officer of concerned Dist

